



September 3, 2021

Avalon Elementary School
235 32nd Street
Avalon, NJ 08202

Dear Avalon Elementary School Community:

Our school system is committed to protecting student, teacher, and staff health. To protect our community and be in compliance with the Department of Education regulations, our District tested our schools' drinking water for lead. In accordance with the Department of Education regulations, Avalon Elementary School implemented immediate remedial measures for one drinking water outlet that had a result greater than the action level of 15 µg/l (parts per billion [ppb]). This included turning off the outlet and replacing the faucet. School was not in session during the time of remediation and all retesting was complete prior to the opening of school in September.

Testing Results

The table below identifies the drinking water outlets that tested above the 15 µg/l for lead, the actual lead level, and what temporary remedial action Avalon Elementary School has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Result in µg/l (ppb)	First Draw Date	Remedial Action	Second Draw Result in µg/l (ppb)	Second Draw Date
Nurses' Office Sink	22.4	8/11/2021	Taken out of service/ Faucet replaced/ School not in session	2.34	9/3/2021

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:00 a.m. and 4:00 p.m. and are also available on our website at www.avalonstoneharborschools.org. For more information about water quality in our schools, contact Kathleen Fox, CSA at the Avalon Stone Harbor Schools at (609) 967-7544.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

Sincerely,

Kathleen Fox

CSA, Avalon Stone Harbor Schools